

# Radon Testing Results - North Lake School District

## Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
North Lake School	Main Building	6th Grade Classroom	3753566	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	Reading Room	3753599	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Library Backroom	3753596	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Library	3753584	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	Gym	3753588	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Gym	3753571	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Gym	3753590	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Kindergarten	3753582	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	1st Grade Classroom	3753583	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Office	3753568	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Speech	3753600	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	2nd Grade Classroom	3753593	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	3rd Grade Classroom	3753585	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	4th Grade Classroom	3753594	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	5th Grade Classroom	3753592	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Art Room	3753587	8/24/2018	Detector Kit	<.4
North Lake School	Ag Science Building	Ag Shop Office	3753580	8/24/2018	Detector Kit	<.4
North Lake School	Ag Science Building	Ag Shop	3753577	8/24/2018	Detector Kit	0.4
North Lake School	Ag Science Building	Ag Shop	3753597	8/24/2018	Detector Kit	<.4
North Lake School	Ag Science Building	Ag Shop	3753604	8/24/2018	Detector Kit	<.4
North Lake School	Ag Science Building	Wood Shop	3753578	8/24/2018	Detector Kit	0.4
North Lake School	Ag Science Building	Wood Shop	3753591	8/24/2018	Detector Kit	<.4
North Lake School	Ag Science Building	Wood Shop	3753589	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	Learning Center	3753572	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	Home Ec	3753569	8/24/2018	Detector Kit	0.6
North Lake School	Main Building	Home Ec	3753570	8/24/2018	Detector Kit	0.8
North Lake School	Main Building	Kitchen	3753567	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Math	3753601	8/24/2018	Detector Kit	0.4

North Lake School	Main Building	Computer Lab	3753602	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	Social Studies	3753573	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	Science	3753586	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	Office	3753576	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Office	3753565	8/24/2018	Detector Kit	0.4
North Lake School	Main Building	Super Office	3753574	8/24/2018	Detector Kit	0.5
North Lake School	Main Building	Health	3753595	8/24/2018	Detector Kit	0.5
North Lake School	Main Building	Neuman Class	3753575	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Faculty	3753579	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	Faculty	3753598	8/24/2018	Detector Kit	<.4
North Lake School	Main Building	ES Computer Lab	3753581	8/24/2018	Detector Kit	<.4
North Lake School	Annex	Annex	3753603	8/24/2018	Detector Kit	0.4