

**Water Testing Results - North Lake School District**  
**Action Level for Lead is 15 parts per billion (ppb)**  
**Action Level for Copper is 1300 parts per billion (ppb)**

Fixture Location/Description	Fixture ID #	Test Date	Test Result Copper	Test Result Lead
Kitchen Sink		8/14/2020	80	3
Laundry Sink		8/14/2020	50	ND
Staff Lounge Sink		8/14/2020	67	ND
Main Office Kitchen Sink		8/14/2020	69	ND
1st Grade Sink		8/14/2020	55	ND
ND = Non Detect - Lead level is below the set detection limits of 2 ppb				
Lab Report is in mg/L - To convert to ppb, multiply by 1,000				